

TRUE/FALSE

1. The 120 VAC circuit is normally protected by a single fuse or circuit breaker.

ANS: T PTS: 1 REF: Protective Factors

2. Switching voltage surges are usually limited to three times normal voltage.

ANS: T PTS: 1 REF: Voltage and Frequency Surges

3. By programming a motor-protective relay unit with the motor's electrical characteristics, the unit's algorithm will automatically tailor the optimal protection curve to the motor being monitored.

ANS: T PTS: 1 REF: Programmable Motor Protection

MULTIPLE CHOICE

1. The typical fuse consists of an element surrounded by a filler and enclosed by the fuse body. The element is a calibrated ____.

a. insulator c. conductor
b. transistor d. capacitor

ANS: C PTS: 1 REF: Fuse Construction and Operation

2. Peak let-thru current (I_p) and ampere squared seconds (I^2t) are two measures for the degree of ____ provided by a fuse.

a. current limitation c. circuit isolation
b. time delay d. rectification

ANS: A PTS: 1
REF: Peak Let-Thru Current (I_p) and Ampere Squared Seconds (I^2t)

3. ____ is the current-limiting characteristic of a transformer and is expressed as a percent.

a. Capacitance c. Ampacity
b. Impedance d. Rectification

ANS: B PTS: 1 REF: Selecting Protective Devices

4. The main purpose of a ground fault circuit interrupter (GFCI) is to ____.

a. determine the interrupting capacity c. protect a person from electrical shock
b. calculate the available current d. gauge the ambient temperature

ANS: C PTS: 1 REF: Ground Fault Circuit Interrupter

COMPLETION

1. All protective devices have a published _____, which is defined as the highest current at rated voltage that a device can safely interrupt.

ANS: interrupting capacity

PTS: 1 REF: Fuse Types

2. _____ fuses are used today in almost all fuse applications.

ANS:

Current-limiting time-delay

Current limiting time delay

PTS: 1 REF: Fuse Types

3. Adding a(n) _____ to the nonautomatic circuit breaker, by using a bimetallic element in each pole of the breaker, provides automatic tripping.

ANS: thermal trip unit

PTS: 1 REF: Circuit Breaker Types